



NOTE:

1. ALL HYDRANT CONNECTIONS MUST BE FIELD INSPECTED, BY A CITY INSPECTOR, PRIOR TO BACKFILLING.
2. ALL PIPE BETWEEN TEE AND FIRE HYDRANT SHALL BE DUCTILE IRON CLASS 52. VALVE SHALL BE RODDED TO SERVICE TEE. VALVE AND HYDRANT SHALL HAVE MEGALUGS OR APPROVED EQUAL.

CITY OF NORFOLK – DEPARTMENT OF UTILITIES
STANDARD DETAILS

SCALE:
NOT TO SCALE

FIRE HYDRANT CONNECTION

DRAWING NO.
CW 05

DATE: 03/07