



NOTES:

1. GRAVEL BEDDING MAY BE USED IN PLACE OF CONCRETE IN NON-TRAFFIC AREA AT DISCRETION OF ENGINEER.
2. MACHINE SEATING SURFACES ON BOTH COVER & FRAME.
3. TOLERANCE TO BE $\pm 0.125"$ FOR ALL DIMENSIONS.
4. CASTING TO BE SHOT BLASTED.
5. CASTINGS TO BE ASTM A48 CLASS 35B.

CITY OF NORFOLK - DEPARTMENT OF UTILITIES
STANDARD DETAILS

SCALE:
NOT TO SCALE

AIR VENT / BLOW-OFF VALVE

DRAWING NO.
CWS 03

DATE: 03/07