

**CITY OF NORFOLK DEPARTMENT OF UTILITIES**  
**DESIGN AND CONSTRUCTION STANDARDS**  
**Appendix F4 – Wastewater Pumping Station Design Checklist**

**General Drawing Requirements**

- 1. The drawings are in accordance with the Standards and use of the Department's standard symbols or an appropriately labeled symbol key.
- 2. The drawings are clear and legible.
- 3. The City Seal is located adjacent to the front door.
- 4. The appropriate applications have been properly filled out and submitted:
  - a. HRSD Flow Certification
  - b. Dominion Virginia Power Request for Service
  - c. Virginia Natural Gas Request for Service
  - d. Department of Environmental Quality (DEQ) Submittal
- 5. Only sanitary wastes are collected and transported – no storm drains or surface water are shown entering the sanitary sewer system.
- 6. Any affected wetland areas or Resource Protection Areas (RPA) are properly shown and labeled.
- 7. Benchmark(s) are identified on the site plan and located every 500 feet along the route of the new sewer force main(s).
- 8. A north arrow and horizontal and vertical scale are included on each sheet, where applicable.
- 9. All existing easements are shown accurately, and proposed utility easements are shown on drawings. The existing easements reflect accurate record information.
- 10. Proposed and existing water and sewer lines are properly labeled with size and type of pipe, and the horizontal and vertical locations shown on the drawings.
- 11. All existing and proposed sanitary sewer, storm sewer, gas, telephone, power, any other utility lines, and all water services which cross or run parallel to the sewer line(s), are shown with horizontal and vertical separations given, where applicable. Subsurface exploration has been performed where potential conflicts exist, where applicable.
- 12. Adjacent road and drainage projects are shown as required.
- 13. Road names, state route numbers, and right-of-way widths are shown.
- 14. Stations ascend from left to right.
- 15. Proposed sewer lines are shown with reference distances from rights-of-way, boundaries, buildings, other utility lines, etc.
- 16. All subdivisions, property lines, and property markers (stones, rods, pins, pipes, monuments, etc.) are shown.

\_\_\_\_\_ 17. Location of existing houses, buildings, fences, wells and other structures are shown on drawings. In lawn or kept areas, trees and shrubs in the easements are shown (size and type).

\_\_\_\_\_ 18. All designs conform to the latest City and State erosion and sediment control rules, regulations, and ordinances.

\_\_\_\_\_ 19. The Design Engineer has coordinated the utility design and construction work with other Design Engineers where their projects connect or affect each other.

\_\_\_\_\_ 20. Locations of special features (concrete encasement, rip-rap stabilization at creek crossings, clay dams, etc.) are shown in sufficient detail.

\_\_\_\_\_ 21. All fill and cut areas are shown within the area of the existing and proposed sewer line(s).

\_\_\_\_\_ 22. Necessary easement plats onsite and/or offsite have been submitted in accordance with the Norfolk City Surveyor's Requirements for processing.

\_\_\_\_\_ 23. Pavement replacement and/or landscaping details are shown on all drawings.

\_\_\_\_\_ 24. Proposed and existing ground elevations are shown.

\_\_\_\_\_ 25. Contract Documents (drawings and specifications) have been submitted to the State Health Department for review and approval where applicable. A copy of transmittal letter is attached to checklist.

\_\_\_\_\_ 26. Alignment of utility in existing Virginia Department of Transportation (VDOT) right-of-way is consistent with City and VDOT guidelines. A copy of a transmittal letter to VDOT for their review is attached. The Design Engineer understands that a letter of approval from VDOT is required prior to final utility plan approval.

\_\_\_\_\_ 27. All sanitary sewer drawings are labeled with size, grade, length, direction of flow, and type and class of pipe(s) (with backup calculations on the type & class pipe needed, where applicable).

\_\_\_\_\_ 28. Manholes are labeled with rim and invert elevations; coordinates; and locations, size and inverts of drop stacks.

\_\_\_\_\_ 29. Deflection angles at all manholes or bearings of all lines are shown on the drawings.

\_\_\_\_\_ 30. Manholes are spaced a maximum of 300 feet apart.

\_\_\_\_\_ 31. All minimum finished floor elevations and basement elevations are to be shown on drawings, where applicable.

\_\_\_\_\_ 32. Ground coverage over sewer pipe meets the minimum criteria of 36-inches.

\_\_\_\_\_ 33. Is emergency pump connection shown and does it conform to standard detail?

\_\_\_\_\_ 34. Is an adequate buffer zone shown around the pumping station?

\_\_\_\_\_ 35. Is there an ample driveway that allows for the largest Department of Utilities vehicle to access the pumping station?

## **Wet Well Drawing Requirements**

- \_\_\_\_\_ 36. Is the wet well access hatch easily accessible and free from obstructions?
- \_\_\_\_\_ 37. Are the bar screen and emergency bypass channel shown and are they easily accessible for maintenance?
- \_\_\_\_\_ 38. Are the alarm levels and elevations shown?
- \_\_\_\_\_ 39. Is the wet well designed to prevent solids deposition?
- \_\_\_\_\_ 40. Is the wet well designed to prevent free-fall of sewer influent during normal operation?
- \_\_\_\_\_ 41. Is there an isolation valve on the sewer influent line located in a valve vault outside of the wet well?
- \_\_\_\_\_ 42. Is all interior metal Type 316L stainless steel?
- \_\_\_\_\_ 43. Are all electrical fixtures in the wet well explosion-proof?
- \_\_\_\_\_ 44. Are there appropriate flow-measuring device(s) and pressure recording device(s) shown?
- \_\_\_\_\_ 45. Is an appropriate coating specified for the interior of the wet well?

## **Pump Room Drawing Requirements**

- \_\_\_\_\_ 46. Is there sufficient (minimum 3 feet) clearance between pieces of equipment, pipes, and structural elements?
- \_\_\_\_\_ 47. Is there sufficient access and handling equipment to facilitate removal and reinstallation of pumps and motors? Does the beam extend through the door to facilitate loading and unloading?
- \_\_\_\_\_ 48. Is the sump pump properly sized with the discharge into the wet well above the wet well high-level elevation?
- \_\_\_\_\_ 49. All lights and switches easily accessible?
- \_\_\_\_\_ 50. All valve operators shall be accessible from the pump room floor or stair landing.
- \_\_\_\_\_ 51. Is there an appropriate backflow prevention device on any potable water supply line?
- \_\_\_\_\_ 52. Is there a gate valve on the suction line?
- \_\_\_\_\_ 53. Is there a check valve and a gate valve on the discharge line?
- \_\_\_\_\_ 54. Is the control system in accordance with Department Standards?
- \_\_\_\_\_ 55. Is there sufficient lighting? Is the lighting shielded?

## **Design Considerations**

- \_\_\_\_\_ 56. Does the pumping station meet the requirements of Class I Reliability?
- \_\_\_\_\_ 57. Has a capacity analysis of the influent collection system been completed in accordance with the Department Standards?
- \_\_\_\_\_ 58. Has a pump sizing analysis been completed in accordance with the Department Standards?

- 59. If the pumps are larger than 50 hp, has the Design Engineer performed a cost analysis to determine if three or more pumps is more cost effective for the Department?
- 60. Has the system curve been determined and transposed to a manufacturer's pump performance curve?
- 61. Has hydraulic transient control been considered by the Design Engineer?
- 62. Has a ventilation analysis been completed to ensure proper air changes in the wet well and the pump house?
- 63. Is the lifting equipment properly sized for the largest piece of equipment in the pumping station?
- 64. Has the effect of hydraulic thrust been considered and addressed?