


NOTE:

1. LOCATION OF WYE, CLEANOUT, AND END OF PIPE MAY BE VARIED BY INSPECTOR IF NECESSARY BECAUSE OF UNUSUAL DEPTH OR CONDITIONS. DI MAIN REQUIRES WYE OR TEE IN COMPLIANCE WITH ANSI A 21.10 LATEST REVISION. LATERAL PIPING SHALL MATCH MAIN LINE PIPE.
2. CONTRACTOR WILL BE REQUIRED TO REMOVE & REPLACE AS MUCH OF ANY EXISTING LATERAL NECESSARY TO ENSURE THAT THE PROPOSED CONNECTION IS MADE IN ACCORDANCE WITH THE DETAIL AT NO ADDITIONAL COST TO THE CITY, INCLUDING MISCELLANEOUS RIGHT-OF-WAY AND PRIVATE PROPERTY IMPROVEMENTS.
3. TRACER WIRE SHALL BE INSTALLED CONTINUOUSLY FROM THE MAIN TO THE RIGHT OF WAY LINE DIRECTLY ON TOP OF THE PVC LATERAL. TRACER WIRE SHALL BE ATTACHED TO THE LATERAL.
4. WHERE A 6-INCH CLEANOUT IS CALLED OUT, THE CONNECTION TO THE MAIN SHALL BE A 6-INCH WYE. THE LATERAL SHALL BE 6-INCH DIAMETER AND THE CLEANOUT SHALL BE 6 INCHES.
5. CLEANOUT SHALL BE LOCATED AT THE PROPERTY LINE AND PREFERABLY IN GRASS. CLEANOUT MAY ALSO BE LOCATED IN SIDEWALK OR DRIVEWAY BUT NOT DRIVEWAY APRON.



DATE: 07/25

CITY OF NORFOLK – DEPARTMENT OF UTILITIES
STANDARD DETAILS

SCALE:
NOT TO SCALE

TYPICAL WYE/LATERAL LAYOUT
AND PROPERTY LINE CLEANOUT

DRAWING NO.
CS 10