



**NOTE:**  
 1. COMPACT AROUND BRASS STANDPIPE TO 95% MODIFIED PROCTOR.  
 2. SAMPLE STATION TO BE LOCATED OUTSIDE OF R/W CLEAR ZONE.

# WATER SAMPLING STATION

NOT TO SCALE

REFERENCE 200, 801	CATEGORY WATER	DATE 6/16	SHEET No. 1 OF 1	DETAIL No. WD_13
-----------------------	-------------------	--------------	---------------------	---------------------