

Decorative Materials:

- * Shall not be suspended from the ceiling.



Storage:

- * Shall not be placed in exit pathways or aisles.



- * Shall be 24" from ceiling or 18" from the sprinkler heads.



The Norfolk Fire Marshal's Office

Wishes Everyone...

"Happy Holidays and a Happy New Year"

If you have any questions about your

Holiday Decorations

Please Contact Us

Prior to Purchasing..

Norfolk Fire Marshal's Office


100 Brooke Avenue, #400

Norfolk, Virginia 23510

Phone: 757-664-6604



HOLIDAY SEASON



FIRE SAFETY AND CODES FOR COMMERCIAL BUILDINGS



Electrical:

- * Check all cuts, breaks and open wires.



- * Do not use extension cords.

- * Don't staple wiring, use proper hangers.



- * If light strings have been used for 2 seasons or more consider replacing.

- * Do not overload electrical breakers. Taping open/locking open breakers is illegal.

- * Follow manufacturers' recommendations for maximum allowed connected strings of lights.



(Generally no more than 3 strings of connected lights are allowable).

- * Cutting and splicing of light strings is not permitted and voids the UL Listing of the product.

- * Cutting and splicing of light strings is not permitted and voids the UL Listing of the product.

Open Flames:

- * Open flames are permitted with the following restrictions:



- The flame is fully contained in a fire proof holder.
- The device is stable and secured on a non-combustible surface.

- * Never leave candles unattended.



- * Open flames are not permitted on or near decorative vegetation.



Fresh Greenery:

- * Live greenery is not recommended in businesses and not permitted in most occupancies, with the exception of Churches.
- * Permitted live greenery shall be held by a secure device, which is capable of holding a two day supply of water.
- * Permitted live greenery and other decorations shall not be displayed in a manner where it can block or obstruct any exit way or pedestrian path of travel.

