

GREASE CONTROL DEVICE CLEANING GUIDE

how to properly clean small grease control devices (under 50 gallons)

TOOLS & MATERIALS

1. A large trash can
2. Two or three trash can liners/bags (thick or heavy duty) or sealable containers
3. Absorbent material (floor dry available at auto parts stores or clay kitty litter)
4. Proper hand tools and safety equipment to open GCD: hex head wrench (allen wrench), screw driver/small pry bar, scraper, rubber gloves and safety glasses
5. Tools for removing contents
 - a. scoop of some type for removal of water and solids
 - b. scraper (putty knife)
 - c. wet/dry vacuum
6. Clean paper towels or cloth rags

askHRgreen.org

Why Clean Your Grease Control Device Frequently?

FEWER SMELLS & ODORS

The longer waste is trapped, the stronger the odors.

LONGER GCD LIFE

Rotting foods create acids which eat away at the internal components and tank, reducing the lifespan of your GCD and leading to increased repair and replacement costs.

CLEAN WITH EASE

The more frequently the GCD is cleaned, the easier it will be.

NO CLOGS

Regular cleanings help keep sewer pipes clean and reduce backups due to clogged lines.

BEFORE YOU CLEAN

1. Develop a strict maintenance schedule and adhere to it. The GCD should be cleaned out completely when 25% of its volume is grease and settled solids, or a minimum of once per week.
2. Prepare your work area (clear area of debris, bleach, bottles, and other cleaners).
3. Line the trash can with garbage bags.
4. Add absorbent material (floor dry or kitty litter) into the lined trash can. This will soak up the water and liquid waste making transport of waste to the dumpster cleaner and safer.
5. Refer to the installation manual for disassembly of the unit.

CLEANING YOUR GCD

1. Turn fasteners counter-clockwise to loosen and carefully remove the lid of the GCD without damaging the gasket.
2. Observe the manner in which the internal parts are installed because you'll have to reinstall them properly after you finish cleaning the trap.
3. Begin removing contents of the grease trap by scooping and vacuuming the waste products from the inside of the trap. Empty contents into trash bag or seal-able container.
4. Remove all contents until GCD is completely empty.
5. Do NOT use hot water, degreasers, or soaps to clean the interior of the GCD.
6. Scrape all the inside walls, baffles, and screens to ensure movement of water through unit.
7. Inspect and note the condition of tank, baffle, and all removable parts. Schedule repairs or replacement as needed.
8. Make sure the GCD has been properly reassembled (all internal parts are in their proper place).
9. Examine the gasket for damage. Replace if necessary - never use tube silicone as a gasket.
10. Clean and re-install rubber gasket and reposition lid on tank. Ensure all screws and hold-downs are in place and properly tightened.
11. Ensure enough absorbent material has been placed in bag to soak up all excess liquids. Add more if needed. Securely tie the bag of waste closed so that it does not leak.
12. Place bag or sealed container in the garbage dumpster or designated receptacle. It is **ILLEGAL** to dump GCD or kitchen waste into the **sanitary sewer system (toilets, clean-outs, manholes, etc.)**, storm drains, ponds, or outdoor Areas.

REPORTING & DOCUMENTATION

1. Contact your local utility for sample grease control device maintenance logs to be kept on site.
2. Maintain documentation and report grease trap cleanings as required by your local FOG ordinance.